Report No:SCEPL/MT/Jun/12/01/01/2020-21 Date:08.07.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Jun/12/01
Agency	KIRDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	05.06.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M30
*Location	CC Pavement

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	Jun/10/01-13	10.06.2020	08.07.2020	150.0	150.0	149.9	22500	8.050	690.9	30.71	30.12
	Jun/10/01-14	10.06.2020	08.07.2020	150.0	149.9	150.0	22485	8.100	680.7	30.27	
	Jun/10/01-15	10.06.2020	08.07.2020	149.9	150.0	149.8	22485	8.250	660.5	29.38	
2	Jun/10/01-16	10.06.2020	08.07.2020	150.0	150.0	149.9	22500	8.050	669.9	29.77	29.84
	Jun/10/01-17	10.06.2020	08.07.2020	150.0	149.9	150.0	22485	8.100	672.7	29.92	
	Jun/10/01-18	10.06.2020	08.07.2020	149.9	150.0	149.8	22485	8.250	670.5	29.82	

Remarks:-

The results pertain to the samples received and tested.
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate
* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

BVH CONSULTING ENGINEER PVT LTD Bangalore

Sarath -NK
AE/JE

Page 1/1

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/Jun/12/01/01/2020-21 Date:08.07.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Jun/12/02
Agency	KIRDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	12.06.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M30
*Location	CC Pavement

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
3	Jun/10/01-19	10.06.2020	08.07.2020	150.0	150.0	149.9	22500	8.050	690.9	30.71	30.12
	Jun/10/01-20	10.06.2020	08.07.2020	150.0	149.9	150.0	22485	8.100	680.7	30.27	
	Jun/10/01-21	10.06.2020	08.07.2020	149.9	150.0	149.8	22485	8.250	660.5	29.38	
4	Jun/10/01-22	10.06.2020	08.07.2020	150.0	150.0	149.9	22500	8.050	669.9	29.77	29.84
	Jun/10/01-23	10.06.2020	08.07.2020	150.0	149.9	150.0	22485	8.100	672.7	29.92	
	Jun/10/01-24	10.06.2020	08.07.2020	149.9	150.0	149.8	22485	8.250	670.5	29.82	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

CONSULTIG ENGINEER Bangalore

Page 1/1

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/Jun/17/01/01/2020-21

Date:22.06.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Jun/17/01
Agency	KIRDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	17.06.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/7 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M30
*Location	CC Pavement

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	Jun/15/01-01	15.06.2020	22.06.2020	150.0	150.0	149.9	22500	8.050	445.9	19.82	19.43
	Jun/15/01-02	15.06.2020	22.06.2020	150.0	149.9	150.0	22485	8.100	426.7	18.98	
	Jun/15/01-03	15.06.2020	22.06.2020	149.9	150.0	149.8	22485	8.250	438.5	19.50	
2	Jun/15/01-04	15.06.2020	22.06.2020	150.0	150.0	149.9	22500	8.050	455.9	20.26	20.03
	Jun/15/01-05	15.06.2020	22.06.2020	150.0	149.9	150.0	22485	8.100	441.7	19.64	
	Jun/15/01-06	15.06.2020	22.06.2020	149.9	150.0	149.8	22485	8.250	453.5	20.17	
3	Jun/15/01-07	15.06.2020	22.06.2020	150.0	150.0	149.9	22500	8.050	464.9	20.66	20.31
	Jun/15/01-08	15.06.2020	22.06.2020	150.0	149.9	150.0	22485	8.100	456.7	20.31	
	Jun/15/01-09	15.06.2020	22.06.2020	149.9	150.0	149.8	22485	8.250	448.5	19.95	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

CONSULTIG ENGINEER PVT LTD Bangalore

Smitha. N K
AE WO

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama@gmail.com

Scanned with CamScanner

Date:22.06.2020

Report No:SCEPL/MT/Jun/17/01/01/2020-21

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Jun/17/02
Agency	KIRDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	17.06.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/7 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M30
*Location	CC Pavement

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
4	Jun/15/01-10	15.06.2020	22.06.2020	150.0	150.0	149.9	22500	8.050	445.9	19.82	19.43
	Jun/15/01-11	15.06.2020	22.06.2020	150.0	149.9	150.0	22485	8.100	426.7	18.98	
	Jun/15/01-12	15.06.2020	22.06.2020	149.9	150.0	149.8	22485	8.250	438.5	19.50	
5	Jun/15/01-13	15.06.2020	22.06.2020	150.0	150.0	149.9	22500	8.050	455.9	20.26	20.03
	Jun/15/01-14	15.06.2020	22.06.2020	150.0	149.9	150.0	22485	8.100	441.7	19.64	
	Jun/15/01-15	15.06.2020	22.06.2020	149.9	150.0	149.8	22485	8.250	453.5	20.17	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

BVH CONSULTING ENGINEER PVT. LTD. Bangalore

AE WIO

Page 2/2

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

Scanned with CamScanner

Report No:SCEPL/MT/Jun/17/01/01/2020-21

Date:13.07.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP. Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Jun/17/01
Agency	KIRDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	17.06.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M30
*Location	CC Pavement

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	Jun/15/01-16	15.06.2020	13.07.2020	150.0	150.0	149.9	22500	8.050	690.9	30.71	30.12
	Jun/15/01-17	15.06.2020	13.07.2020	150.0	149.9	150.0	22485	8.100	680.7	30.27	
	Jun/15/01-18	15.06.2020	13.07.2020	149.9	150.0	149.8	22485	8.250	660.5	29.38	
2	Jun/15/01-19	15.06.2020	13.07.2020	150.0	150.0	149.9	22500	8.050	669.9	29.77	29.84
	Jun/15/01-20	15.06.2020	13.07.2020	150.0	149.9	150.0	22485	8.100	672.7	29.92	
	Jun/15/01-21	15.06.2020	13.07.2020	149.9	150.0	149.8	22485	8.250	670.5	29.82	
3	Jun/15/01-22	15.06.2020	13.07.2020	150.0	150.0	149.9	22500	8.050	670.9	29.82	30.13
	Jun/15/01-23	15.06.2020	13.07.2020	150.0	149.9	150.0	22485	8.100	692.7	30.81	
	Jun/15/01-24	15.06.2020	13.07.2020	149.9	150.0	149.8	22485	8.250	669.5	29.78	

Remarks:-

The results pertain to the samples received and tested.
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate
* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

Sweetha.N.L
AE W/O

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bangaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama88@gmail.com

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/Jun/17/01/01/2020-21

Date:13.07.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Jun/17/02
Agency	KIRDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	17.06.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M30
*Location	CC Pavement

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
4	Jun/15/01-25	15.06.2020	13.07.2020	150.0	150.0	149.9	22500	8.050	690.9	30.71	30.12
	Jun/15/01-26	15.06.2020	13.07.2020	150.0	149.9	150.0	22485	8.100	680.7	30.27	
	Jun/15/01-27	15.06.2020	13.07.2020	149.9	150.0	149.8	22485	8.250	660.5	29.38	
5	Jun/15/01-28	15.06.2020	13.07.2020	150.0	150.0	149.9	22500	8.050	669.9	29.77	29.84
	Jun/15/01-29	15.06.2020	13.07.2020	150.0	149.9	150.0	22485	8.100	672.7	29.92	
	Jun/15/01-30	15.06.2020	13.07.2020	149.9	150.0	149.8	22485	8.250	670.5	29.82	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

CONSULTING ENGINEER PVT. LTD. BANGALORE

AE WIU

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli Bangalore-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED
(Mechanical Testing Laboratory Division)
ISO 9001:2015

Report No:SCEPL/MT/May/10/01/01/2020-21 **Date:10.05.2020**

TEST REPORT

***Client Name& Address:**	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
***Name of Work:**	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
***Letter Reference:**	No:BBMP/EE/BTP/WO/208/2020-21 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/May/10/01
Agency	KRIDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	10.05.2020
Sample Type/Size/ Grade/Age:	Cover Slab cube/150mmx150mmx150mm/7 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
***Grade of concrete**	M20
***Location**	U Drain cover Slab

Compressive strength of Concrete cover Slab

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	Cover Slab/10-01	03.05.2020	10.05.2020	150.4	150.0	149.9	22566	8.050	365.9	16.21	16.17
	Cover Slab/10-02	03.05.2020	10.05.2020	150.9	150.9	151.0	22768	8.100	376.7	16.55	
	Cover Slab/10-03	03.05.2020	10.05.2020	150.9	150.7	150.8	22741	8.250	358.5	15.76	

Remarks:-

The results pertain to the samples received and tested.
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate
* Information furnished by the client

*** End of the report***

SHIPRAMA CONSULTING ENGINEERS PVT. LTD. Bangalore

Authorized Signatory

CONSULTING ENGINEERS Bangalore

AE W10

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/May/10/01/2020-21 **Date:31.05.2020**

TEST REPORT

***Client Name& Address:**	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
***Name of Work:**	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
***Letter Reference:**	No:BBMP/EE/BTP/WO/208/2020-21 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/May/10/01
Agency	KRIDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	10.05.2020
Sample Type/Size/ Grade/Age:	CC Cover Slab/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
***Grade of concrete**	M20
***Location**	U Drain Cover Slab

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	Cover Slab/10-04	03.05.2020	31.05.2020	151.0	151.0	151.1	22801	8.050	516.9	22.67	22.57
	Cover Slab/10-05	03.05.2020	31.05.2020	150.8	150.9	150.2	22756	8.100	495.7	21.78	
	Cover Slab/10-06	03.05.2020	31.05.2020	150.9	150.0	150.8	22635	8.250	526.5	23.26	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

BVK CONSULTING ENGINEER PVT LTD Bangalore

Shiprama Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

AE BJO

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli . Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED
(Mechanical Testing Laboratory Division)
ISO 9001:2015

Report No:SCEPL/MT/May/26/01/01/2020-21 **Date:26.05.2020**

TEST REPORT

***Client Name& Address:**	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
***Name of Work:**	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
***Letter Reference:**	No:BBMP/EE/BTP/WO/208/2020-21 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/May/26/01
Agency	KRIDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	26.05.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/7 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
***Grade of concrete**	M20
***Location**	U Drain Cover Slab

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	May/26/CS-01	19.05.2020	26.05.2020	150.9	150.0	151.0	22632	8.050	340.0	15.02	15.57
	May/26/CS-02	19.05.2020	26.05.2020	150.6	150.7	150.0	22689	8.100	353.2	15.57	
	May/26/CS-03	19.05.2020	26.05.2020	150.9	150.0	150.5	22635	8.250	365.1	16.13	

Remarks:-

The results pertain to the samples received and tested.
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate
* Information furnished by the client

*** End of the report***

SHIPRAMA CONSULTIG ENGINEERS PVT.LTD. Bangalore

Authorized Signatory

Suvitha. N.L
AE L10

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/May/26/01/01/2020-21 **Date:16.06.2020**

TEST REPORT

***Client Name& Address:**	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
***Name of Work:**	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
***Letter Reference:**	No:BBMP/EE/BTP/WO/208/2020-21 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/May/26/01
Agency	KRIDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	26.05.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
***Grade of concrete**	M20
***Location**	U Drain Cover Slab

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	May/26/CS-04	19.05.2020	16.06.2020	150.0	150.0	150.0	22500	8.050	495.9	22.04	22.18
	May/26/CS-05	19.05.2020	16.06.2020	150.0	151.0	150.6	22650	8.100	517.7	22.86	
	May/26/CS-06	19.05.2020	16.06.2020	151.0	150.0	151.5	22650	8.250	490.5	21.66	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers P. Ltd. Bangalore

Authorized Signatory

CONSULTIG ENGINEER P. LTD. Bangalore

Suvetha N R
AE ward 10

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/May/31/01/01/2020-21 **Date:31.05.2020**

TEST REPORT

***Client Name& Address:**	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
***Name of Work:**	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
***Letter Reference:**	No:BBMP/EE/BTP/WO/208/2020-21 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/May/31/01
Agency	KRIDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	31.05.2020
Sample Type/Size/ Grade/Age:	Cover Slab cube/150mmx150mmx150mm/7 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
***Grade of concrete**	M20
***Location**	U Drain cover Slab

Compressive strength of Concrete cover Slab

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	Cover Slab/10-01	24.05.2020	31.05.2020	150.4	150.0	149.9	22566	8.050	335.9	14.89	15.29
	Cover Slab/10-02	24.05.2020	31.05.2020	150.9	150.9	151.0	22768	8.100	346.7	15.23	
	Cover Slab/10-03	24.05.2020	31.05.2020	150.9	150.7	150.8	22741	8.250	358.5	15.76	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA CONSULTIG ENGINEER P. LTD. BYH Bangalore

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

AE W10

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/May/31/01/01/2020-21 **Date:21.06.2020**

TEST REPORT

***Client Name& Address:**	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
***Name of Work:**	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
***Letter Reference:**	No:BBMP/EE/BTP/WO/208/2020-21 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/May/31/01
Agency	KRIDL
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	31.05.2020
Sample Type/Size/ Grade/Age:	CC Cubes/150mmx150mmx150mm/28 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
***Grade of concrete**	M20
***Location**	U Drain Cover Slab

Compressive strength of Concrete cube

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	May/26/CS-04	24.05.2020	21.06.2020	150.0	150.0	150.0	22500	8.050	520.9	23.15	22.48
	May/26/CS-05	24.05.2020	21.06.2020	150.0	151.0	150.6	22650	8.100	492.7	21.75	
	May/26/CS-06	24.05.2020	21.06.2020	151.0	150.0	151.5	22650	8.250	510.5	22.54	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA CONSULTING ENGINEERS PVT. LTD. Bangalore

Authorized Signatory

Suvetha .NK
AE/JIO

Page 1/1

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/Mar/20/01/01/2020-21 Date:25.03.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Mar/20/01
Agency	
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	20.03.2020
Sample Type/Size/ Grade/Age:	Cover Slab cube/150mmx150mmx150mm/7 days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M15
*Location	U drain Pcc & Coping

Compressive strength of Concrete cover Slab

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	May/18/01-01	18.03.2020	25.03.2020	150.4	150.0	149.9	22566	8.050	275.9	12.23	11.46
	May/18/01-02	18.03.2020	25.03.2020	150.9	150.9	151.0	22768	8.100	258.7	11.36	
	May/18/01-03	18.03.2020	25.03.2020	150.9	150.7	150.8	22741	8.250	245.5	10.80	
2	May/18/01-04	18.03.2020	25.03.2020	150.4	150.0	149.9	22566	8.050	275.9	12.23	11.77
	May/18/01-05	18.03.2020	25.03.2020	150.9	150.9	151.0	22768	8.100	266.7	11.71	
	May/18/01-06	18.03.2020	25.03.2020	150.9	150.7	150.8	22741	8.250	258.5	11.37	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA CONSULTIG ENGINEER PVT. LTD. Bangalore

Shiprama Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

Suvetha. ML
AE W10

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner

SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(Mechanical Testing Laboratory Division)

ISO 9001:2015

Report No:SCEPL/MT/Mar/20/01/01/2020-21

Date:15.04.2020

TEST REPORT

*Client Name& Address:	Asst. Executive Engineer Vidyaranya Pura Sub Division BBMP, Bangalore.
*Name of Work:	Improvements to Roads and Drains at Doddabommasandra Old village , Subbanna Beedi and Surrounding areas in ward No 10 Doddabommasandra
*Letter Reference:	No:BBMP/EE/BTP/WO/208/2019-20 Dated- 10.03.2020
SCEPL ID	SCEPL/MT/2020/Mar/20/01
Agency	
Source of Sample:	Samples supplied by the Customer
Date of Receipt:	20.03.2020
Sample Type/Size/ Grade/Age:	Cover Slab cube/150mmx150mmx150mm/ 28days Compressive Strength
Reference to BIS codes:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
*Grade of concrete	M15
*Location	U drain Pcc,Coping

Compressive strength of Concrete cover Slab

Sl. No.	Identification mark	Date of Casting	Date of Testing	Dimension of the Specimen mm			Cross sectional area (Sq.mm)	Weight (kg)	Failure Load (kN)	Compressive strength (N/mm2)	Average Compressive Strength (N/mm^2)
				L	B	H					
1	May/18/01-07	18.03.2020	15.04.2020	150.4	150.0	149.9	22566	8.050	340.0	15.07	15.55
	May/18/01-08	18.03.2020	15.04.2020	150.9	150.9	151.0	22768	8.100	353.2	15.51	
	May/18/01-09	18.03.2020	15.04.2020	150.9	150.7	150.8	22741	8.250	365.1	16.05	
2	May/18/01-10	18.03.2020	15.04.2020	150.4	150.0	149.9	22566	8.050	375.0	16.62	16.46
	May/18/01-11	18.03.2020	15.04.2020	150.9	150.9	151.0	22768	8.100	366.7	16.11	
	May/18/01-12	18.03.2020	15.04.2020	150.9	150.7	150.8	22741	8.250	378.5	16.64	

Remarks:-

The results pertain to the samples received and tested.

Any correction in the report will make this report invalid

This report without prior written approval should not be reproduced or published in full or part.

Samples will be disposed after 90 days from the date of issue of test certificate

* Information furnished by the client

*** End of the report***

SHIPRAMA Consulting Engineers Pvt. Ltd. Bangalore

Authorized Signatory

CONSULTING ENGINEERS

AE W10

Assistant Executive Engineer
Vidyaranyapura Sub Division
BBMP, Bangalore - 97

1048, 8th Block Extension ,Gangubai Hangal Road, Sir M. Vishveshwaraiah Layout, Near Gidadakonenahalli
Bengaluru-560091.Mob:9886212878 Ph.: 080 29554444 | Email: shiprama888@gmail.com |

Scanned with CamScanner